




Centennial Coal



Angus Place Colliery

Temporary Water Treatment Plant Water Monitoring Program

September 2018

DOCUMENT CONTROL

DOCUMENT DETAILS	Name:	Angus Place Colliery – Temporary Water Treatment Plant Water Monitoring Program	
	Author:	Lachlan Hammersley (Centennial Coal)	
	Revision No.:	2	
	Document Status	Final	
APPROVAL DETAILS	Revision No.	Trigger	Details of change
	1	EPL 467 condition U1.2	
	2	Review of operational requirements following Project approval and varied EPL	Administrative changes to achieve consistency with varied EPL Additional text and figures around changes to LDP001 location

Table of Contents

1	INTRODUCTION	1
2	POLLUTION REDUCTION PROGRAM.....	1
3	SCOPE.....	1
4	PROPOSED MONITORING PROGRAM	1
4.1	SURFACE WATER	1
4.2	GROUNDWATER	3
4.3	MONITORING DURATION.....	4
5	MONITORING PROGRAM JUSTIFICATION	4

Tables

TABLE 1 - MONITORING PROGRAM FOR UPSTREAM AND DOWNSTREAM SAMPLING ON WOLGAN RIVER.....	1
TABLE 2 - MONITORING PROGRAM FOR LDP001	2
TABLE 3 - MONITORING PROGRAM FOR GROUNDWATER BORE AND UNDERGROUND SAMPLING	3

Figures

FIGURE 1 – PROPOSED SURFACE WATER MONITORING LOCATIONS	5
FIGURE 2 – PROPOSED WATER QUALITY MONITORING BOREHOLE LOCATION	6
FIGURE 3 – PROPOSED UNDERGROUND WATER QUALITY MONITORING POINT	7
FIGURE 4 – LDP001 LOCATION AS PER MODIFIED EPL.....	8

1 Introduction

Centennial Angus Place Pty Limited (Centennial Angus Place) operates Angus Place Colliery (Angus Place) under Project approval PA 06_0021. On 11 May 2018, the Environment Protection Authority (EPA) issued Centennial Angus Place a variation to the Angus Place Colliery Environment Protection Licence (EPL 467).

The EPL variation imposed a Pollution Reduction Program (PRP) requiring the treatment of water discharged via the Angus Place Colliery Licenced Discharge Point LDP001 and authorised:

- The establishment and operation of a temporary water treatment plant, utilising reverse osmosis techniques, and ancillary infrastructure comprising water transfer pipelines and a 1 ML Mine Water Tank; and
- The management of waste stream from the water treatment plant through emplacement within the underground workings at Angus Place.

2 Pollution Reduction Program

In accordance with the new Condition U1.1 on EPL 467, Centennial Angus Place is required to install, by 31 August 2018, a reverse osmosis water treatment system that will treat all mine water discharged at LDP1 to an electrical conductivity of 350 µS/cm.

Condition U1.2 of the EPL requires Centennial Angus Place to prepare a monitoring program, in consultation with the EPA, to monitor the EC levels in District 800 and in the Wolgan River prior to commissioning of the reverse osmosis system.

3 Scope

This monitoring program has been prepared to satisfy the requirements of EPL 467 Condition U1.2 and to identify changes to water quality as a result of the emplacement of the waste stream from the water treatment plant within the underground workings at Angus Place.

4 Proposed monitoring program

4.1 Surface water

Monitoring is proposed to be undertaken at two locations on the Wolgan River, located upstream and downstream (refer to **Figure 1**) of any possible area of seepage via the outcropping Lithgow Seam. The following surface water monitoring program provided in **Table 1** is proposed.

Table 1 - Monitoring program for upstream and downstream sampling on Wolgan River

Parameter	Frequency*
Physicochemical	
pH, EC, TSS, Flow, total alkalinity, bicarbonate alkalinity (as CaCO ₃), turbidity, oil and grease, temperature	Monthly

Parameter	Frequency*
Metals (dissolved and total)	
Aluminium, arsenic **, barium, boron, copper, iron, manganese, nickel and zinc	
Major ions	
Sodium, calcium, magnesium, potassium, sulfate, chloride, bicarbonate ion	
Other	
Surfactants	

* Current assessment predictions indicate the time frame for seepage to occur is likely to be in excess of the life of the Project and hence the risk is low. Therefore it is unlikely that the monitoring will identify any issues and hence the monthly frequency is proposed.

** Arsenic total concentration to consider III and V.

Monitoring of the LDP001 discharge point as a result of the Project will move from the existing v-notch weir concrete pit structure, to the recommissioned diffuser system, as is indicated in **Figure 4**. As part of the varied EPL the monitoring at LDP001 is to remain at a sampling frequency of monthly (minimum of 1 samples per 4 weeks). Similarly, the existing monitoring parameters sampled at LDP001 will be unchanged as is summarised in **Table 2**.

Table 2 - Monitoring program for LDP001

Parameter	Frequency*
Physicochemical	
pH, EC, TSS, total alkalinity, bicarbonate alkalinity (as CaCO ₃), turbidity, oil and grease, temperature, dissolved oxygen, TDS	
Metals (dissolved and total)	Monthly
Aluminium, arsenic, barium, boron, copper, iron, manganese, nickel, zinc, lead, cadmium [^] , uranium [^] , lithium [^] , molybdenum [^] , rubidium [^] , strontium [^] , and antimony [^]	
Nutrients	
Nitrate, nitrite, total nitrogen, nitrite+nitrate, TKN, total phosphorus, ammonia as N, total fluoride.	

Parameter	Frequency*
Major ions	
Sodium, calcium, magnesium, potassium, sulfate, chloride, bicarbonate ion, total hardness	
Other	
Surfactants, chlorine free and total, silica, silicon, total phenolics, TOC, Total cyanide	

^{*}sampling only dissolved concentrations of metals

4.2 Groundwater

One groundwater monitoring bore will be installed down-dip (north east) from the workings to allow for early detection of any potential seepage migration (refer to **Figure 2**). Underground quality sampling will also be undertaken to monitor changes in the chemistry of the stored water (refer to **Figure 3**). Potential migration/seepage from underground stored water will be detected based on a change in water level or chemistry at the groundwater bore.

The following groundwater monitoring program provided in **Table 3** is proposed.

Table 3 - Monitoring program for groundwater bore and underground sampling

Parameter	Frequency
Physicochemical	
pH, EC, TSS, water level (bore only), total alkalinity, bicarbonate alkalinity (as CaCO ₃), turbidity, oil and grease, temperature	
Metals (dissolved and total)	
Aluminium, arsenic **, barium, boron, copper, iron, manganese, nickel and zinc	Monthly
Major ions	
Sodium, calcium, magnesium, potassium, sulfate, chloride, bicarbonate ion	
Other	
Surfactants	

** Arsenic total concentration to consider III and V.

4.3 Monitoring duration

Monitoring is to occur from the commencement of injection activities. A period of monitoring following the completion of the Project will also be considered which will be a minimum period of 12 months or until stored underground water returns to pre-project conditions (storage level and quality).

Where monitoring locations are already established, and co-purposed for other operations, then these points will not be decommissioned but will return to the management of the site.

5 Monitoring program justification

Monitoring locations have been proposed based on accessibility and location to potential seepage locations. Where possible monitoring locations utilise existing locations where a good history of monitoring data exists.

Monitoring parameters recommended generally include those parameters that are going to be indicative of the source of water. The source of water will be a mixture of groundwater and treatment plant residuals. Typically treatment plants undergo pilot testing that can identify typical quality concentrations of treated and residual streams, however these are not available. We do however have typical information on an equivalent scenario through the works done for the Springvale Water Treatment Plant.

From existing groundwater testing we know that Angus Place has the following chemical signature to its extracted groundwater:

- Elevated dissolved metal fractions of: arsenic, barium, boron, and molybdenum.
- Elevated total metal fractions of: aluminium, arsenic , barium, boron, copper, and iron.
- Zinc, nickel, and manganese not elevated compared to Springvale Mine however monitoring is still required as they are common indicator parameters.

As there is minimal difference between the total and dissolved fractions of the parameters required, assessment of both fractions across all identified metals is proposed.



Angus Place Colliery
Water Treatment Plant Project
Wolgan River Monitoring Locations



Figure 1

A3



LEGEND

- River/Creek
- Colliery Holding Boundary
- Tracks
- Newnes Plateau Shrub Swamp (DECC)

CENTENNIAL ANGUS PLACE PTY. LTD

THIS DRAWING IS COPYRIGHT
NO PART OF IT IN ANY FORM OR BY ANY MEAN
(ELECTRONIC, MECHANICAL, MICRO-COPYING,
PHOTOCOPYING OR OTHERWISE) BE REPRODUCED
STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED
WITHOUT PRIOR WRITTEN PERMISSION

REFERENCES

D. DATE 4.06.20

SEAM LITHGO

MEANS SCALE DIAGRAM ON

G,
ICED, DRAWN Alan M

CHECKED by NA

C:\ACE\Jobs for Devon Roberts\2018.05.03\APC_WTP_Wolgan River

Angus Place Colliery
Water Treatment Plant Project
Proposed Water Quality
Monitoring Borehole Location
(Adjacent to Wolgan River)





Centennial Coal

Angus Place

DRG. No. Figure 2

A3


LEGEND

In Situ Water

CENTENNIAL ANGUS PLACE PTY. LTD.

THIS DRAWING IS COPYRIGHT

NO PART OF IT IN ANY FORM OR BY ANY MEANS
(ELECTRONIC, MECHANICAL, MICRO-COPYING,
PHOTOCOPYING OR OTHERWISE) BE REPRODUCED,
STORED IN A RETRIEVAL SYSTEM OR TRANSMITTED
WITHOUT PRIOR WRITTEN PERMISSION

REFERENCE

N:\SHARED\DWGS\WEST\SURFACE\Jobs for Devon Roberts\2018.05.03\APC_WTP_Underground Monitoring Point.dwg

DATE 8.06.2018

SEAM LITHGOW

SCALE DIAGRAM ONLY

DRAWN Alan Mellor

CHECKED by NA

**Angus Place Colliery
Water Treatment Plant Project
Proposed Underground Water Quality
Monitoring Point**
(for 800 Region via inseam boreholes at P910N 28ct stub)

DRG. No. Figure 3

A3



Angus Place Colliery
Plan Showing
Licenced Discharge Points



Centennial Coal
Fassifern

DATE 05-07-2018

PC6795

LOCATION	Angus Place
SEAM	
DRAWN	C.P.T.
CHECKED	J.W.
APPROVED	P.C.D.
SCALE	Refer to scalebar